



MUNICIPAL CORPORATION CHANDIGARH

(Public Health Laboratory at Water Works Sector - 39)

TEST - REPORT

Not for legal use

Lab No. : MCPHL/26/ 472

Date : 05.03.2026

Ref. No. : GMHS/12/2025-26/145	Sample Details	Date & Time
Dated : 24.02.2026	Collected By : Laboratory Staff	
Issued to : The Headmistress Govt. Model High School, Sector - 12, Chandigarh	Collection Date : 02.03.2026	06:50 a.m.
Location : From School tap of Govt. Model High School, Sector - 12, Chandigarh	Received at Lab : 09:15 a.m.	
Packing : Polypropylene and glass bottle		

Test Result (As Per BIS 10500:2012)

S.No	Examination	Quality Standard	Unit	Result
1	pH	6.5 - 8.5	---	7.37
2	Odour	Agreeable	---	Agreeable
3	Taste	Agreeable	---	Agreeable
4	Turbidity	<1	N.T.U.	0.4
5	Total Dissolved Solids	<500	mg/l	306
6	Residual Chlorine	0.2 - 0.4	mg/l	0.2
7	Total Alkalinity (as CaCO ₃)	<200	mg/l	288
8	Total Hardness (as CaCO ₃)	<200	mg/l	224
9	Chlorides (as Cl)	<250	mg/l	09
10	Free & Saline Ammonia	NIL	mg/l	NIL
11	M.P.N. of Coliform Bacilli / 100ml of water	Zero	M.P.N.	0 (Excellent)

Payment received vide receipt No. 02/2025-26/304376, dated 27.02.2026, amount Rs.-3300/-

Note: - Water sample is found "POTABLE".

Chemist,
M.C.P.H. Laboratory,
Chandigarh.

Sub Divisional Engineer,
M.C.P.H. Sub Division No.1,
Chandigarh.

Endst. No. MCPH/26/-----

Copy forwarded to the Medical Officer of Health Municipal Corporation, Sector - 17, Chandigarh for information please.

Dated : 05.03.2026

Chemist,
M.C.P.H. Laboratory,
Chandigarh.

Sub Divisional Engineer,
M.C.P.H. Sub Division No.1,
Chandigarh.

Remarks:-

- The results given above are related to the sample as collected and tested in lab.
- The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- The test report can't be used for any publicity or legal purpose.

----- End of Report -----

WATER IS LIFE, SAVE IT